

6.2 सुरक्षा ऑडिट



DURVA FIRE AND SAFETY SOLUTIONS
12-B, Parijal colony, Deapur, Dhule(MH) 424002
+91-86986 14666, 9423193769
contact@dfssindia.com
www.dfssindia.com
GST No.27BOZPJ1686K1Z0

Date:-04/01/2024

CERTIFICATE

TO WHOMSOEVER IT MAY CONCERN

**M/S. SHRI CHHATRAPATI SHIVAJI SAINIKI VIDYALAYA MORANE PR
NER.TAL-DIST-DHULE**

THIS IS CERTIFY THAT THE ORDER NOTED FIRE EX TENGUISHERS HAVE BEEN
TESTED BY US HYDROLOGICALLY AND REFILLED AS PER RULES.

D.C.P / W.CO2 /CO2/ AFFF FOAM / ABC FIRE EXTINGUISHERS HAS BEEN H.P. TESTED
ON 30KG.F./CM2 AS PER IS SPECIFICATION.

Date:- 04/01/2024 TO 03/01/2025

Sr. No.	Description	Fire Extinguishers Capacity.	Total Numbers of Fire Extinguisher ^l Refilled/ Servicing	Remark
1.	ABC Type Fire Extinguisher	6 kg.	28	OK
2.	CO2 Type Fire Extinguisher	4.5 kg.	02	OK



Authorized Signature

For DURVA Fire And Safety Solutions